

# Internally Restrained Joint Identification

## Suggested Specification

All internally restrained PVC pipe joints shall be clearly indicated as restrained by a suitable identification on the bell end of the pipe. This identification shall indicate the product used to effect the restraint. The identification shall be a waterproof, indelible tape such as Powerseal Rhino Tuff PS82 (or equal) wrapped at least 75% around the circumference of the pipe bell. This tape shall be at least two inches wide with the name of the restraining product (e.g. RieberLok) clearly visible and unequivocally indicating that the joint is restrained.



**Example: Restrained Joint Identification**